

**TYPE APPROVAL CERTIFICATE****This is to certify:****That the Electric Power Cable**with type designation(s)  
**LMGSGO (P1 RFOU) 0,6/1 kV**

Issued to

**Untel Kablolari San. ve Tic. A.S.**  
**Dilovasi, Turkey**

is found to comply with

**Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards**  
**IEC 60092-353 (2011-08)**  
**IEC 60332-3-22 (2009-02)**  
**IEC 60754-1 (2011-11)**  
**IEC 60754-2 (2011-11)**  
**IEC 61034-2 Ed. 3.1 (2013-06)**  
**NEK TS 606 (2009-05)****Application :****General power and lighting. Flame retardant Cat. A.**  
**Halogen free. Low smoke. Cold bend (-30°C) and impact (-30°C).****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Voltage class (kV) 0,6/1**  
**Temp. class (°C) 90**This Certificate is valid until **2019-06-23**.Issued at **Høvik** on **2015-06-24**DNV GL local station: **Istanbul**Approval Engineer: **Georgy Abramenko**for **DNV GL**.....  
**Marit Laumann**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

## Product description

Type: LMGSGO (RFOU) 0,6/1 kV

Construction:

Conductors: Tinned stranded copper  
 Core insulation: XLPE  
 Inner covering: Halogen free compound  
 Metal covering: Tinned copper wire braid  
 Outer sheath: SHF2

Number of cores x conductor cross-section mm <sup>2</sup>
2 x 1,5
2 x 2,5
3 x 1,5
3 x 2,5
4 x 1,5
4 x 2,5
5 x 1,5

Number of cores x conductor cross-section mm <sup>2</sup>
5 x 2,5
7 x 1,5
7 x 2,5
10 x 1,5
12 x 1,5
14 x 1,5
16 x 1,5

Number of cores x conductor cross-section mm <sup>2</sup>
19 x 1,5
24 x 1,5
27 x 1,5
33 x 1,5
37 x 1,5

## Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

Data sheets: FR 72-520 REV.2 REV. TAR 03.12.2010  
 Test reports: Dated 16.09.2010

## Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2008-02	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen

Job Id: **262.1-008110-2**  
Certificate No: **TAE000002R**

<b>Standard</b>	<b>Release</b>	<b>General description</b>	<b>Limitation</b>
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke
NEK 606 Ed. 4	2009-05	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	Mud resistance test: IRM903 100°C 7d. Calcium Bromide 70°C 56d. <u>Oil based mud:</u> Carbo Sea 70°C 56d or EDC 95/11 70°C 56d

### Marking of product

Üntel – LMGSGO (RFOU) – size – IEC 60332-3-22 Cat A. –NEK 606 – 0,6/1 kV

### Periodical assessment

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE