



## TYPE APPROVAL CERTIFICATE


No. ELE052516XT/006

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

<i>Description</i>	<b>ELECTRIC CABLES</b>
<i>Type</i>	<b>MGH 0.6/1 kV</b>
<i>Applicant</i>	<b>UNTEL KABLOLARI SANAYI VE TICARET A.S.</b>
<i>Manufacturer</i>	<b>UNTEL KABLOLARI SANAYI VE TICARET A.S.</b>
<i>Place of manufacture</i>	<b>MAKINE O.S.B. 6.CADDE, NO.4 DILOVASI 41455 KOCAELI TURKEY</b>
<i>Reference standards</i>	<b>DIN 89160, IEC 60092-350</b>

Issued in **ISTANBUL** on **October 11, 2016**. This Certificate is valid until **October 10, 2021**



  
RINA Services S.p.A.  
Cinar Kutlar

This certificate consists of this page and 1 enclosure

**TYPE APPROVAL CERTIFICATE**

No. ELE052516XT/006

**Enclosure - Page 1 of 1**

**MGH 0.6/1 kV**

**Materials/Components**

Shipboard power cables, flame retardant, halogen free with low smoke emission, for ships and off-shore units installation.

Rated voltage: 0.6/1 kV

Type: MGH

Marking: UNTEL DIN 89160 IEC 60092-353 MGH n x s mm<sup>2</sup> 0.6/1 kV IEC 60332/3A

Construction:

conductor: stranded copper wire class 2 or 5, tinned on request

insulation: HF-EPR

bedding: halogen free compound

sheath: SHF1

Max. conductor temperature: 90°C.

In accordance to rules DIN 89160; IEC 60228 ; IEC 60092-350; IEC 60092-353; IEC 60092-360; IEC 60332-1-2; IEC 60332-3-22; IEC 60754-1; IEC 60754-2; IEC 61034-1; IEC 61034-2.

Conductor size:

number of cores 1 - cross sectional area from 1.5 to 300 mm<sup>2</sup>

number of cores 2, 3, 4 - cross sectional area from 1 to 300 mm<sup>2</sup>

number of cores 5 - cross sectional area from 1 to 240 mm<sup>2</sup>

number of cores 7 - cross sectional area from 1 to 4 mm<sup>2</sup>

number of cores 10,12,14,16, 18, 19, 20, 21, 24, 25, 27, 30, 32, 34, 36, 37 - cross sectional area from 1 to 2.5 mm<sup>2</sup>

Technical specification: data sheet N. FR 70-040 Rev1 dated 01/07/2011.

**ISTANBUL 11.10.2016**

G