



**TYPE APPROVAL CERTIFICATE**  
No. ELE035611XT/003

**This is to certify** that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

<i>Description</i>	<b>ELECTRIC CABLES</b>
<i>Type</i>	<b>MYY 0.6/1 kV</b>
<i>Applicant</i>	<b>UNTEL KABLOLARI SANAYI VE TICARET A.S. ALEMDAG CAD., SITE YOLU. No.26 34768 UMRANIYE, ISTANBUL TURKEY</b>
<i>Manufacturer</i>	<b>UNTEL KABLOLARI SANAYI VE TICARET A.S.</b>
<i>Place of manufacture</i>	<b>ALEMDAG CAD., SITE YOLU. No.26 34768 UMRANIYE, ISTANBUL TURKEY</b>
<i>Reference standards</i>	<b>IEC 60092-350; IEC 60092-353</b>

Issued in **ISTANBUL** on **August 3, 2011**. This Certificate is valid until **August 2, 2016**



RINA  
**Orhan Pekcay**

This certificate consists of this page and 1 enclosure



**TYPE APPROVAL CERTIFICATE**

No. **ELE035611XT/003**

Enclosure - Page 1 of 1

**MYY 0.6/1 kV**

**Materials/Components**

Shipboard power cables, flame retardant, for ships and off-shore units installation.

Rated voltage: 0.6/1 kV

Type: MY Y

Marking: UNTEL IEC 60092-353 MY Y n x s mm<sup>2</sup> 0.6/1 kV IEC 60332/3A

**Construction:**

conductor: stranded annealed copper wire class 2 or 5, tinned on request

insulation: PVC

bedding: rubber compound bedding

sheath: PVC

Max. conductor temperature: 75°C.

In accordance to rules IEC 60228 ; IEC 60092-350; IEC 60092-351; IEC 60092-353; IEC 60092-359; IEC 60332-1-2; IEC 60332-3-22.

**Conductor size:**

number of cores 1 - cross sectional area from 1.5 to 300 mm<sup>2</sup>

number of cores 2, 3, 4 - cross sectional area from 1 to 300 mm<sup>2</sup>

number of cores 5 - cross sectional area from 1 to 240 mm<sup>2</sup>

number of cores 7 - cross sectional area from 1 to 4 mm<sup>2</sup>

number of cores 10,12,14,16, 18, 19, 20, 21, 24, 25, 27, 30, 32, 34, 36, 37 - cross sectional area from 1 to 2.5 mm<sup>2</sup>

Technical specification: data sheet N. FR 70-070 Rev1 dated 01/07/2011.

**ISTANBUL August 3, 2011**