

CERTIFICATE

Issued to:
Applicant:
Üntel Kalolari San Ve Tic A.S.
Makine O.S.B. 6 Cad. No. 4
41455 Kocaeli Dilovasi
Turkey

Manufacturer/Licensee:
Üntel Kalolari San Ve Tic A.S.
Makine O.S.B. 6 Cad. No. 4
41455 Kocaeli Dilovasi
Turkey

Product : XLPE insulated and PVC sheathed cable with improved fire performance and combined armour/protective earth conductor
Trade name : UNTEL
Type : VG-YMvKasmb

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:
a type test according to the standard KEMA 42C-1-4-D:1995 based on HD 604 S1:1994/A3:2005 (Part 4 Section D) and additional IEC 60332-3-22:2000/A1:2008
– an inspection of the production location according to CENELEC Operational Document CIG 021
– a certification agreement with the number 2144451

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 11 April 2012 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2152268.04

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION

