

TYPE APPROVAL CERTIFICATE

Certificate no.:
TAE000040N
Revision No:
1

This is to certify:

that the **Electric Power Cable**

with type designation(s)
M2XCH-FFR VFD

issued to

Untel Kablolari San. ve Tic. A.S.
Dilovası, Türkiye

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Rated voltage (kV) **1,8/3**
Temp. class (°C) **90**

Issued at **Høvik** on **2026-01-21**

This Certificate is valid until **2030-07-02**.

DNV local unit: **Istanbul**

Approval Engineer: **Ivar Bull**



for **DNV**

This document has been digitally signed and will
therefore not have handwritten signature

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Type: M2XCH-FFR VFD 1,8/3 kV

Conductor: Stranded copper class 2 or class 5
 Insulation: XLPE + Mica Tape
 Inner covering: Halogen Free Compound
 Armour / braid: CU/PETP Tape + Copper wire braid
 Outer sheath: SHF1

Variant No	Number of cores x conductor cross-section [mm ²]	Approx outer diameter [mm]
1	3x50 + 3G10	39,2
2	3x70 + 3G16	43,9
3	3x95 + 3G16	47,1
4	3x120 + 3G25	52

Manufactured by

Untel Kablolari San. ve Tic. A.S.
 Demirciler Köyü Makine OSB 6. Cadde No 4
 41455 Dilovası
 Turkey

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

General power and lighting.
 Fire resistant. Flame retardant in bunch Cat. A. Low smoke.

Type Approval documentation

Test report: Untel Kablolari San. ve Tic. A.S., No: T19030-R00, dated 18/09/2019
 ÜNTELE LABORATUVARI, No: 202507210, dated 2025/11/05

Specification: Untel Kablolari San. ve Tic. A.S., 12/2019
 M2XCH FFR VFD, No: 45810-12363-1, dated 2025/06/02

Type approval renewal assessment report for Kocaeli 2025-06-04

Tests carried out

Standard	Release	General description	Limitation
DNV-CP-0399	2021-08	Class Programme Electric cables	
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2024-06	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-1-2	2025-06	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	

Standard	Release	General description	Limitation
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	
IEC 60331-1	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	For outer Sheath only Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	For outer Sheath only Halogen free: pH > 4,3 Conductivity<10µS/mm
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

Untel Kablolari San. ve Tic. A.S. – M2XCH-FFR VFD – Size – 1,8/3kV – IEC 60331-1 – IEC 60332-3-22 Cat.A – Lot no.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE