

CERTIFICATE

Issued to:
Applicant:
Üntel Kablolari San Ve Tic A.S.
Makine O.S.B. 6 Cad. No. 4
41455 Kocaeli Dilovasi, Türkiye

Licensee:
Üntel Kablolari San Ve Tic A.S.
Makine O.S.B. 6 Cad. No. 4
41455 Kocaeli Dilovasi, Türkiye

Product : Flexible cables with crosslinked elastomer insulation
Trade name(s) : UNTEL or VOIFLEX
Type(s)/model(s) : H07BQ-F

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 50525-1:2011, EN 50525-1:2011/A1:2022 and EN 50525-2-21:2011
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2144451


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 5 June 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2197262.01 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

| | |
|---------------------------------|--|
| Product | : Flexible cables with crosslinked elastomer insulation |
| Trade name(s) | : UNTEL or VOIFLEX |
| Type(s)/model(s) | : H07BQ-F |
| Rated voltage | : 450/750 V |
| Conductor | : Copper class 5 |
| Conductor operating temperature | : 90°C maximum |
| Insulation | : Cross-linked elastomeric compound of type EI6 to EN 50363-1 |
| Oversheath | : Thermoplastic polyurethane of type TMPU to EN 50363-10-2 |
| Tested cables | : 5G1,0 mm ² 2x16 mm ² |
| Certified cables | : 2x1,0 mm ² up to and including 2x16 mm ² 3x1,0 mm ² up to and including 3x16 mm ² 4x1,0 mm ² up to and including 4x16 mm ² 5x1,0 mm ² up to and including 5x16 mm ² 3G1,0 mm ² up to and including 3G16 mm ² 4G1,0 mm ² up to and including 4G16 mm ² 5G1,0 mm ² up to and including 5G16 mm ² |

TESTS**Test requirements**

EN 50525-1:2011
EN 50525-1:2011/A1:2022
EN 50525-2-21:2011

Test result

The test results are documented in DEKRA test file 219726200, 229929000.

Additional information

This certificate replaces certificate No. 2197262.01 which we hereby declare invalid.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Üntel Kablolari San Ve Tic A.S.
Makine O.S.B. 6 Cad. No. 4
41455 Kocaeli Dilovasi, Türkiye